



Addendum No. 1

To Bid Package for

REVERSE OSMOSIS MEMBRANES FOR WATER TREATMENT PLANT

Monday, March 14, 2016

NOTICE TO ALL BIDDERS

All bidders are to make the following clarifications to the Bid Package. Include signed Addendum No. 1 with bid or email acknowledgement to DNguyen@BeverlyHills.org

CLARIFICATIONS:

1. Pressure drop data for each individual RO element is not required in Certificates of Analysis.
2. Specifications call for feed spacer to be 0.028 and 0.031 inches, however a feed spacer of 0.034 inches is also acceptable.

Derek Nguyen, Ph.D., P.E.
City of Beverly Hills – Public Works Services Dept.

By signing below, the bidder acknowledges receipt of this Addendum No. 1 on this _____ day of _____, 2016.

Bidder: _____

By: _____